

**CRYOGENIC TEST PROCEDURE AT -196°C
ACCORDING TO THE TECHNICAL SPECIFICATION FMC FE117_000_rev8_fr**

AUDIT COMPANY: _____ DATE: 22/07/11

DOC. REF Nr: CRYO TEST_03_11 DRAWING Nr: _____

VALVE FIG.: 515 BORE: 3"

SEAT MATERIAL: TFM-1600 RATING: ANSI 150 LBS.

BODY: MATERIAL / EAT Nr: CP8M / RTZ TEMPERATURE: -196°C

CONNECTOR: MATERIAL / EAT Nr: A316 / 99574

1. GENERAL CONDITIONS:

- The valve must have passed successfully the standard JC tests.
- The valve must be thoroughly cleaned and degreased.
- To install one thermocouples in the bore of the valve (internal)
- The fluid used to detect leakage is helium.

2. TEST PROCEDURE:

COOLING PROCESS AT -196°C

- During the cooling time let helium circulate inside the valve at 0.5 Bar (to avoid ice formation inside)
- The test can be started when the temperature of the valve is -190°C.

WORKING PROCESS TEST AT -196°C

- Close the valve and relieve the downstream pressure.
- Pressurize for the upstream at test pressure (22 bar).
- Open and close the valve, measure and record the valve opening and closing torques.

OPENING TORQUE (mKg)	CLOSING TORQUE (mKg)
<u>20</u>	<u>25</u>

LEAKAGE TEST AT -196°C

- Leave the valve half open and relieve pressure in the circuit.
- Close the valve and pressurize at test pressure (22 bar)

TEST PRESSURE	MAXIMUM LEAKAGE ALLOWED	DETECTED LEAKAGE
22 bar	45 ml / min. (15 ml x inch)	0 ml/min

WARMING-UP PROCESS

- After having completed the tests, leave the valve half-open and de-pressurize the whole circuit.
- Disconnect the valve form the circuit.
- Leave the valve to warm-up up to ambient temperature.
- Make a visual inspection without disassembling the valve.


REALIZED: TONI AGUILERA
R&D Department**CHECKED: JOSÉ TEJEDOR**
Technical Manager

7270

DN	L	A	φP	h1	h	H	M	Sch.
2"	178	89	50	254	835	4.09	213	4.0
3"	203	101.5	80	254	111	4.60	4.45	4.0

NOTE 1

DN 2: 17-4 PH
 DN 3: AISI 304



DN	BALL VALVE. FREE STEM DIMENSIONS						WEIGHT (kg)	QUANTITY	ITEM
	φA	B	C	φD	E	F			
2"	55	39.5	17.6	70	3	M8	M18x1.5	11	-
3"	70	44.5	19	102	3	M10	M25x1.5	23.5	-



(*) RECOMMENDED SPARE PARTS

POS.	QUAN.	DENOMINATION	MATERIAL
2	1	PLASTIC CAP	PLASTIC
7980	4	WASHER	AISI 316
912	4	BOLT	A. 193 Gr. B8M
89	1	IDENTIFICATION PLATE	STAINLESS STEEL
72	1	"O" RING	FKM
68	1	EXTENSION SHELL	A. 351 Gr. CF8M
46	1	LOCKING WASHER	AISI 304
41	1	SPACER	AISI 304
40	1	GASKET	GRAPHITE
39	1	STEM BUSHING	AISI-316 WITH INSIDE IN PIPE
28	1	NUT	A. 194 Gr. BM
19	1	ANTISTATIC DEVICE	STAINLESS STEEL
18	1	THRUST WASHER	PIPE + 50% S.S.
17	1	WASHER	AISI 304
16	1	BOLT	DIN-933 A2
15	1	STUD	A. 193 Gr. B8M
14	2	STOP PIN	STAINLESS STEEL
13	1	BODY CONNECTOR SEAL	AISI 316L + GRAPHITE
12	1	STEM THRUST SEAL	PIPE + 50% S.S.
11	2	GLAND PACKING	GRAPHITE
10	1	GLAND	AISI 316
9	1	STOP PLATE	NOTE 1
8	2	DISK SPRING	INCONEL 718
7	1	GLAND NUT	AISI 303
6	1	WRENCH	A. 216 Gr. WCB
5	1	SEAT RING	IFM
4	1	STEM	NITRONIC 50
3	1	BALL	A. 351 Gr. CF8M
2	1	BODY CONNECTOR	AISI 316L
1	1	BODY	A. 351 Gr. CF8M

Rev.	Modification	Drawn	Checked	Appr. Eng.	Scale:	Substitutes:	Substitutes by:
1	3 Features	T. Aguiar	J. Rubio			7270 Rev.0	
0	First Issue						

Rev.	Date	Nam.	Approv.
05-11	J.R.		
04-11	J.A.		

		JC Fábrika de válvulas, s.a. 08830 Sant Boi de Llobregat (Spain) Tel + (34) 936 54 86 86 // Fax + (34) 936 86 87 e mail: technical@jc-ballvalves.com	
Ref:		Ref:	
Drawing nº:		Drawing nº:	
7270		7270	

This drawing is our property. It is strictly forbidden to use the drawing, to give it to third parties or to reproduce it totally or partially without our permission.



**CRYOGENIC TEST PROCEDURE AT -196°C
ACCORDING TO THE TECHNICAL SPECIFICATION FMC FE117_000_rev8_fr**

AUDIT COMPANY: _____ DATE: 26/07/11
 DOC. REF Nr: CR40 TEST_04_11 DRAWING Nr: _____
 VALVE FIG.: 515 BORE: 2"
 SEAT MATERIAL: TPM-1600 RATING: ANSI 150 LBS.
 BODY: MATERIAL / EAT Nr: CF8M / RT2 TEMPERATURE: -196°C
 CONNECTOR: MATERIAL / EAT Nr: A316 / 99548

1. GENERAL CONDITIONS:

- The valve must have passed successfully the standard JC tests.
- The valve must be thoroughly cleaned and degreased.
- To install one thermocouples in the bore of the valve (internal)
- The fluid used to detect leakage is helium.

2. TEST PROCEDURE:

COOLING PROCESS AT -196°C

- During the cooling time let helium circulate inside the valve at 0.5 Bar (to avoid ice formation inside)
- The test can be started when the temperature of the valve is -190°C.

WORKING PROCESS TEST AT -196°C

- Close the valve and relieve the downstream pressure.
- Pressurize for the upstream at test pressure (22 bar).
- Open and close the valve, measure and record the valve opening and closing torques.

OPENING TORQUE (mKg)	CLOSING TORQUE (mKg)
<u>7</u>	<u>7,5</u>

LEAKAGE TEST AT -196°C

- Leave the valve half open and relieve pressure in the circuit.
- Close the valve and pressurize at test pressure (22 bar)

TEST PRESSURE	MAXIMUM LEAKAGE ALLOWED	DETECTED LEAKAGE
22 bar	<u>30</u> ml / min. (15 ml x inch)	0 ml/min

WARMING-UP PROCESS

- After having completed the tests, leave the valve half-open and de-pressurize the whole circuit.
- Disconnect the valve from the circuit.
- Leave the valve to warm-up up to ambient temperature.
- Make a visual inspection without disassembling the valve.


REALIZED: TONI AGUILERA
R&D Department**CHECKED: JOSÉ TEJEDOR**
Technical Manager

7270

DN	L	A	φP	h1	h	H	M	Sch.
2"	178	89	50	254	83.5	4.09	213	4.0
3"	203	101.5	80	254	111	4.60	4.45	4.0

NOTE 1

DN 2" 17-4 PH
DN 3" AISI 304



(*) RECOMMENDED SPARE PARTS

POS.	QUAN.	DENOMINATION	MATERIAL	DRAWING N°.
2	1	PLASTIC CAP	PLASTIC	
4	1	WASHER	AISI 316	
912	4	BOLT	A 193 Gr. B8M	
89	1	IDENTIFICATION PLATE	STAINLESS STEEL	
72	1	"O" RING	FKM	*
68	1	EXTENSION SHELL	A 351 Gr. CF8M	*
46	1	LOCKING WASHER	AISI 304	*
41	1	SPACER	AISI 304	*
40	1	GASKET	GRAPHITE	*
39	1	STEM BUSHING	AISI-315 WITH INSIDE IN PIPE	*
28	--	NUT	A 194 Gr. B8M	
19	2	ANTISTATIC DEVICE	STAINLESS STEEL	
18	1	THRUST WASHER	PTFE + 50% S.S.	*
17	1	WASHER	AISI 304	
16	1	BOLT	DIN-933 A2	
15	--	STUD	A 193 Gr. B8M	
14	2	STOP PIN	STAINLESS STEEL	
13	1	BODY CONNECTOR SEAL	AISI 316L + GRAPHITE	*
12	1	STEM THRUST SEAL	PTFE + 50% S.S.	*
11	2	GLAND PACKING	GRAPHITE	*
10	1	GLAND	AISI 316	
9	1	STOP PLATE	NOTE 1	
8	2	DISK SPRING	INCONEL 718	
7	1	GLAND NUT	AISI 305	
6	1	WRENCH	A 216 Gr. WCB	
5	1	SEAT RING	1FM	
4	1	STEM	NITRONIC 50	
3	1	BALL	A 351 Gr. CF8M	
2	1	BODY CONNECTOR	AISI 316L	
1	1	BODY	A 351 Gr. CF8M	

Rev.	Modification	Drawn	Checked	Appr. Eng.	Scale:	Substitutes:	Substitutes by:
1	J Positions	20-04-11	T Aguilera				
0	First issue	20-04-11	J Rubio				
Dimensions		mm.					
Weight:							
Substitutes:							
7270 Rev.0							
Substitutes by:							

Delte	Nam.	Approv.
05-11	JR	
04-11	J.A.	

		JC
Fábrcica de válvulas, s.a. 08830 Sant Boi de Llobregat (Spain) Tel + (34) 934 84 86 / Fax + (34) 934 86 87 e mail: technical@jc-ballvalves.com		Ref.:
GENERAL DIMENSIONS FIG. 516 II, FM, DN2" & 3" CLASS 150 BW FB CRYOGENIC SERVICE		Drawing n°.: 7270

This drawing is our property. It is strictly forbidden to use the drawings, to give it to third parties or to reproduce it totally or partially without our permission.

**CRYOGENIC TEST PROCEDURE AT -196°C
ACCORDING TO THE TECHNICAL SPECIFICATION FMC FE117_000_rev8_fr**

AUDIT COMPANY: _____ DATE: 6/09/2011
 DOC. REF Nr: CRYO TEST 05-11 DRAWING Nr: _____
 VALVE FIG.: 530 BORE: 1"
 SEAT MATERIAL: TFM-1600 RATING: ANSI 300 Lbs.
 BODY: MATERIAL / EAT Nr: CF8M / 1E70 TEMPERATURE: -196°C
 CONNECTOR: MATERIAL / EAT Nr: CF8M / 1E70

1. GENERAL CONDITIONS:

- The valve must have passed successfully the standard JC tests.
- The valve must be thoroughly cleaned and degreased.
- To install one thermocouples in the bore of the valve (internal)
- The fluid used to detect leakage is helium.

2. TEST PROCEDURE:

COOLING PROCESS AT -196°C

- During the cooling time let helium circulate inside the valve at 0.5 Bar (to avoid ice formation inside)
- The test can be started when the temperature of the valve is -190°C.

WORKING PROCESS TEST AT -196°C

- Close the valve and relieve the downstream pressure.
- Pressurize for the upstream at test pressure (56 bar).
- Open and close the valve, measure and record the valve opening and closing torques.

OPENING TORQUE (mKg)	CLOSING TORQUE (mKg)
<u>4,5</u>	<u>5,5</u>

LEAKAGE TEST AT -196°C

- Leave the valve half open and relieve pressure in the circuit.
- Close the valve and pressurize at test pressure (56 bar)

TEST PRESSURE	MAXIMUM LEAKAGE ALLOWED	DETECTED LEAKAGE
56 bar	<u>15</u> ml / min. (15 ml x inch)	0 ml/min

WARMING-UP PROCESS


- After having completed the tests, leave the valve half-open and de-pressurize the whole circuit.
- Disconnect the valve from the circuit.
- Leave the valve to warm-up up to ambient temperature.
- Make a visual inspection without disassembling the valve.

REALIZED: TONI AGUILERA
R&D Department**CHECKED: JOSÉ TEJEDOR**
Technical Manager

7328

DN	BALL VALVE. FREE STEM DIMENSIONS						WEIGHT (kg)	QUANTITY	ITEM
	φA	B	C	φD	E	F			
1"	35	32.5	14.2	50	1.5	M6	M16 x 1.5	12	-

DN	L	A	φD	φP	h	H1	H	M
1"	165	70	124	25	58	200	322	210



(*) RECOMMENDED SPARE PARTS

POS.	QUAN.	DENOMINATION	MATERIAL	DRAWING N°.
2		PLASTIC CAP	PLASTIC	
7980	4	WASHER	AISI 316	
912	4	BOLT	A 193 Gr. B8M	
89	1	IDENTIFICATION PLATE	STAINLESS ST.	
72	1	O' RING	FKM	*
68	1	EXTENSION SHELL	AISI 316L	
46	1	LOCKING WASHER	AISI 304	*
41	1	SPACER	AISI 304	
40	1	GASKET	GRAPHITE	*
39	1	BUSHING	AISI-316 WITH INSIDE IN PIPE	*
28	4	NUT	A 194 Gr. 8M	
19	2	ANTISTATIC DEVICE	STAINLESS ST.	
18	1	THRUST WASHER	PIEPE + 50% S.S.	*
17	1	WASHER	AISI 304	
16	1	BOLT	DIN-933 A2	
15	4	STUD	A 193 Gr. B8M	
14	2	STOP PIN	STAINLESS ST.	
13	1	BODY CONNECTOR SEAL	AISI 316L + GRAPHITE	*
12	1	STEM THRUST SEAL	PIEPE + 50% S.S.	*
11	2	GLAND PACKING	GRAPHITE	*
10	1	GLAND	AISI 316	
9	1	STOP PLATE	17-4 PH	
8	2	DISK SPRING	EN.P. + CARBON ST.	
7	1	GLAND NUT	AISI 303	
6	1	WRENCH	MODULAR IRON	
5	2	SEAT RING	TFM	*
4	1	STEM	NITRONIC 50	
3	1	BALL	AISI 316	
2	1	BODY CONNECTOR	ASTM A 351 CF8M	
1	1	BODY	ASTM A 351 CF8M	

Rev.	0	First Issue			
Dimensions	17-5-11	J. Rubio			
mm.	17-5-11	J.R.			
Weight:					
Substitutes:					
Substitutes by:					
Drawn	17-5-11	J. Rubio			
Checked	17-5-11	J.R.			
Appr. Eng.					
Scale:					
			Ref.:		
GENERAL DIMENSIONS FIG.530 I.I.TFM DN-1" Class-300 CRYOGENIC SERVICE			Date: 5-11 J.R.		
Fabrica de válvulas, s.a. 08830 Sant Bad de Llobregat (Spain) Tel. + (34) 936 54 86 86 / Fax + (34) 936 86 87 e-mail: technical@ballvalves.com			Drawing n°: 7328		

This drawing is our property. It is strictly forbidden to use, the drawing, to give it to third parties or to reproduce it totally or partially without our permission.